

CLIENT INFORMATION

Client: *****
 Requested On: Feb 17, 2024
 Phone: *****
 Email: *****

hello@gosimplelab.com

EPA LAB ID: OH00218
 158 Starlite Drive
 Marietta, Ohio 45750

TESTING PERFORMED

Testing Requested: PFAS Water Test
 Matrix: Drinking Water
 Testing / Report ID: WYC4TS

SAMPLE INFORMATION

Collection Date: Aug 4, 2024
 Collected By: *****
 Received Date: Aug 8, 2024
 Reported On: Aug 19, 2024
 Sample Location: Post Foot Bath Distilled Water
 Sample Address: *****

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	METHOD	EVALUATION
N-ethyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
N-methyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorobutanesulfonic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorodecanoic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorododecanoic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluoroheptanoic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorohexanesulfonic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorohexanoic acid	µg/L	0.0497	0.00109	EPA 537.1	< HGL
Perfluorononanoic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorooctanesulfonic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorooctanoic acid	µg/L	0.0029	0.00109	EPA 537.1	> HGL (4.0E-6)
Perfluorotetradecanoic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluorotridecanoic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	
Perfluoroundecanoic acid	µg/L	NOT DETECTED	0.00109	EPA 537.1	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. SLR is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the SLR over the course of your lifetime is thought to be safe.

MQL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online. Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin